

Liberty Park Natural Springs - 1300 South 700 East 2020 Data

The information below represents annual sampling for full chemistry and organics. Weekly bacteria testing for total coliform, e-coli and heterotrophic plate count (HPC) also are performed. For any questions concerning these tests and/or results, contact the Water Quality Administrator - Marian Rice at 801-483-6865 or Marian.Rice@slcgov.com.

CHEMISTRY		
Analyte	Results (mg/L or ppm) ¹	EPA Max Contaminant Level ² (mg/L / ppm)
Alkalinity Titration	252	
Aluminum	0.09	0.2 ^a
Ammonia as N	ND ³	
Antimony	ND	0.006
Arsenic	0.0009	0.01
Barium	0.021	2
Beryllium	ND	0.004
Bromide	0.05	
Cadmium	ND	0.005
Calcium	94	
Chloride	50	250
Chromium	ND	0.1
Copper	ND	Action Level ⁴ = 1.3
Fluoride	0.3	4
Hardness	376	
Iron	ND	0.3 ^a
Langelier Index	0.25	
Lead	ND	Action Level = 0.015
Magnesium	34.3	
Manganese	0.0019	
Mercury	ND	0.002
Molybdenum	ND	
Nickel	ND	
Nitrate-N	0.5	10
Nitrite-N	ND	1
Ortho-Phosphate as P	0.04	
Potassium	2.9	
Selenium	0.0026	0.05
Silver	ND	0.1 ^a
Sodium	35.6	
Sulfate	171	250 ^a
Thallium	ND	0.002
Total Cyanide	ND	0.2
Total Dissolved Solids	596	2000 ^b
Total Organic Carbon	0.5	
UV254 cm-1	0.03	

Vanadium	ND	
Zinc	ND	5 ^a
ORGANICS		
Analyte	Results (µg/L or ppb) ⁵	EPA Max Contaminant Level (µg/L / ppb)
Carbamates		
3-Hydroxycarbofuran	ND	
Aldicarb	ND	
Aldicarb sulfone	ND	
Aldicarb sulfoxide	ND	
Carbaryl	ND	
Carbofuran	ND	40
Methomyl	ND	
Oxamyl	ND	200
Herbicides		
2,4,5-TP (Silvex)	ND	50
2,4-D	ND	70
Dalapon	ND	200
Dicamba	ND	
Dinoseb	ND	7
Pentachlorophenol	ND	1
Picloram	ND	500
Pesticides		
Endrin	ND	2
Heptachlor	ND	0.4
Heptachlor epoxide	ND	0.2
Lindane	ND	0.2
Methoxychlor	ND	40
PCB-1016	ND	0.2
PCB-1221	ND	0.5
PCB-1232	ND	0.5
PCB-1242	ND	0.5
PCB-1248	ND	0.5
PCB-1254	ND	0.5
PCB-1260	ND	0.5
PCB - Total	ND	0.5
Toxaphene	ND	3
Semi-Volatile Compounds		
Alachlor	ND	2
Aldrin	ND	
Atrazine	ND	3
Benzo (a) pyrene	ND	0.2
Bis(2-ethylhexyl) adipate	ND	400
Bis (2-ethylhexyl) Phthalate	ND	6

Butachlor	ND	
alpha-Chlordane	ND	2
gamma-Chlordane	ND	2
Chlordane - Total	ND	2
Dieldrin	ND	
Hexachlorobenzene	ND	1
Hexachlorocyclopentadiene	ND	50
Metolachlor	ND	
Metribuzin	ND	
Propachlor	ND	
Simazine	ND	4
Volatile Organic Compounds		
1,1,1,2-Tetrachloroethane	ND	
1,1,1-Trichloroethane	ND	200
1,1,2,2-Tetrachloroethane	ND	
1,1,2-Trichloroethane	ND	5
1,1,2-Trichlorotrifluoroethane	ND	
1,1-Dichloroethane	ND	7
1,1-Dichloroethene	ND	
1,1-Dichloropropene	ND	
1,2,3-Trichlorobenzene	ND	
1,2,3-Trichloropropane	ND	
1,2,4-Trichlorobenzene	ND	70
1,2,4-Trimethylbenzene	ND	70
1,2-Dichlorobenzene	ND	600
1,2-Dichloroethane	ND	5
1,2-Dichloropropane	ND	5
1,3,5-Trimethylbenzene	ND	
1,3-Dichlorobenzene	ND	
1,3-Dichloropropane	ND	
1,4-Dichlorobenzene	ND	75
2,2-Dichloropropane	ND	
2-Chlorotoluene	ND	
4-Chlorotoluene	ND	
Benzene	ND	5
Bromobenzene	ND	
Bromochloromethane	ND	
Bromodichloromethane	ND	
Bromoform	ND	
Bromomethane	ND	
Carbon Tetrachloride	ND	5
Chlorobenzene	ND	100
Chloroethane	ND	
Chloroform	ND	
Chloromethane	ND	
cis-1,2-Dichloroethene	ND	
cis-1,3-Dichloropropene	ND	

Dibromochloromethane	ND	
Dibromomethane	ND	
Dichlorodifluoromethane	ND	
Ethyl Benzene	ND	700
Hexachlorobutadiene	ND	
Isopropylbenzene	ND	
Methyl tert-Butyl Ether (MTBE)	ND	
Methylene Chloride	ND	5
Naphthalene	ND	
n-Butyl Benzene	ND	
n-Propyl Benzene	ND	
p-Isopropyltoluene	ND	
sec-Butyl Benzene	ND	
Styrene	ND	100
tert-Butylbenzene	ND	
Tetrachloroethene	ND	5
Toluene	ND	1000
trans-1,2-Dichloroethene	ND	100
trans-1,3-Dichloropropene	ND	
Trichloroethene	ND	5
Trichlorofluoromethane	ND	
Vinyl Chloride	ND	2
Xylenes, total	ND	10000

¹ Units are in milligrams per liter (µg/L). Milligrams per liter are equivalent to parts per million (1 penny in \$10,000).

² Max Contaminant Level (MCL) - The highest or maximum level of a contaminant that is allowed in drinking water.

³ Non Detect (ND) - Indicates that the analyte was not present in the sample.

⁴ Action Level - The level of lead or copper which, if exceeded in over 10% of homes tested, triggers treatment or other requirements that a water system must follow.

⁵ Units are in micrograms per liter (µg/L). Micrograms per liter are equivalent to parts per billion (1 penny in \$10 million).

^a Secondary Drinking Water Standards MCL

^b Utah State Primary Standard

* Detection of Chloroform may be due to the irrigation of surface areas with chlorinated water.