

## Notes

1. Adhere to Section 4401 and 4407 of the Uniform Building code.
2. Canopies shall be constructed to support a minimum of 150 pounds per square foot live load, uniformly loaded.
3. No Parking signs shall be posted within 50' of each end and at no greater than 100' intervals mounted flush to barricade and 7' minimum above street surface.
4. Walkway width (4' or 8') shall be determined by pedestrian volume or permitting agency.
5. All surfaces shall be painted and maintained white except where orange and white reflectorized hazard markings are required.
6. All lights shall be maintained in working order at all times.
7. Pedestrian approach ramps must be provided at a maximum slope of 10:1 and meet ADA requirements.
8. Optional buried columns may be substituted for angled backside supports if approved by the agency owning the right of way.
9. Protective wire cage or clear lexan fixture with 60-100 watt incandescent lights. Junction boxes and conduit required, placed outside of walkway at 32' on center as well as all entrances and exits. (U.B.C. approved)
10. 7" diameter plastic steady burn electric yellow lights mounted below and outside of handrail spaced 48" on center.