



## Salt Lake City Water Reclamation Facility

### FOG Program

1365 West 2300 North  
Salt Lake City, Utah 84116  
(801) 799-4089

<b>Grease Removal Device (GRD) 90-Day Pump Out Waiver Application</b>
---

<b>Facility Name:</b>		<b>Date:</b>		
<b>Facility Address:</b>		<b>Contact(s):</b>		
		<b>Contact Title:</b>		
<b>Phone:</b>		<b>Email:</b>		

Please furnish all monitoring records for a *minimum* period of 90 days. This includes the **Food Service Establishment Grease Trap Self-Monitoring Checklist** showing compliance with the 25% rule and pumping manifests, if applicable. The waiver request will not be considered without proper documentation.

Please check box to acknowledge that extending the pumping frequency will result in accelerated corrosion and reduced lifespan of the GRD.

		1	2	3	4	
<b>Grease Removal Device (GRD) Quantity:</b>		<b>GRD Size in Gallons:</b>				
<b>Requested # of Waivers:</b>		<b>Frequency of Pump out:</b>				
<b>GRD Servicer:</b>		<b>Date of Last Pump Out:</b>				

***Please Note: A Separate Food Service Establishment GRD Cleaning & Maintenance Log Must Be Submitted For EACH GRD Waiver Requested.***

I certify that this information submitted is, to the best of my knowledge true and complete. I am aware that there are significant penalties for submitting false information, including civil and criminal penalties. This permit

<b>FSE REP Signature:</b>		<b>Date:</b>	
<b>FSE REP Name: (Please Print)</b>			

*For Salt Lake City F.O.G Program use only:*

After careful review of the FSE Grease Removal Device (GRD) monitoring and clean out (pump) frequency records, including the "FSE Gravity Grease Interceptor Self-Monitoring Checklist" for compliance with the 25% rule, a waiver requiring a clean out of the interceptor on a minimum 90-day schedule is hereby:

<input type="checkbox"/> <b>Denied</b>	<input type="checkbox"/> Insufficient record keeping or monitoring frequency	<input type="checkbox"/> Records indicate that the GRD exceeds the 25% rule	<input type="checkbox"/> other
<input type="checkbox"/> <b>Granted</b>	The interceptor shall be pumped-in-full (total pump of all contents) when the total accumulations of FOG including floating solids, and settled solids reaches twenty-five percent 25% of the GRD's overall liquid depth. The FSE is to continue to monitor/inspect the interceptor frequently to ensure compliance with the 25% rule, as well as maintain each " <b>Food Service Establishment GRD Cleaning &amp; Maintenance Log</b> " and "Non-Hazardous Waste Manifest" onsite. These records shall be kept for a minimum of 5 years and be available for inspection. The City retains the right to require an increased pumping and monitoring frequency for interceptors found to be overloaded and not pumped or for failure of the FSE to provide detailed records.		

<b>FOG Program Signature:</b>		<b>Date:</b>	
-------------------------------	--	--------------	--

