

**Table 1 – Wastewater Discharge Local Limits  
Salt Lake City Water Reclamation Facility**

<b>POLLUTANT OF CONCERN (POC)</b>		<b>Local Limit</b>	
<b>METAL POLLUTANTS</b>	Arsenic (As)	0.2	mg/L
	Cadmium (Cd)	0.2	mg/L
	Chromium (Cr)	5.0	mg/L
	Copper (Cu)	6.2	mg/L
	Lead (Pb)	1.5	mg/L
	Mercury (Hg)	0.2	mg/L
	Molybdenum (Mo)	0.8	mg/L
	Nickel (Ni)	1.4	mg/L
	Selenium (Se)	1.0	mg/L
	Silver (Ag)	--	--
	Zinc (Zn)	12.0	mg/L
	<b>ORGANIC/ CONVENTIONAL POLLUTANTS</b>	Biochemical Oxygen Demand (BOD)	11,000
Total Suspended Solids (TSS)		7,200	mg/L
Chemical Oxygen Demand (COD)		--	--
Biodegradable Oil and Grease		500	mg/L
Petroleum, Non-biodegradable Oil		100	mg/L
pH (range)		≥ 5.0 and ≤11.0	standard units

mg/L – milligrams per liter

pH is an instantaneous limit. All other Local Limits are expressed as a daily maximum